DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES OFFICE ENGINEER, MS 43 1727 30TH STREET P.O. BOX 168041 SACRAMENTO, CA 95816-8041 FAX (916) 227-6214 TTY 711



September 20, 2010

08-Riv,SBd-10,62,243-Var 08-478304 Project ID 0800000762 STPHG-000C(322)E

Addendum No. 2

Dear Contractor:

This addendum is being issued to the contract for CONSTRUCTION ON STATE HIGHWAY IN RIVERSIDE AND SAN BERNARDINO COUNTIES AT VARIOUS LOCATIONS.

Submit bids for this work with the understanding and full consideration of this addendum. The revisions declared in this addendum are an essential part of the contract.

Bids for this work will be opened on Thursday, September 23, 2010.

This addendum is being issued to revise the Notice to Bidders and Special Provisions.

In the Special Provisions, Section 10-1.19, "CONCRETE STRUCTURES," subsection "GENERAL," the following paragraph is added after the first paragraph:

"Precast concrete units shall not be used for transition anchor blocks."

To Bid book holders:

Inquiries or questions in regard to this addendum must be communicated as a bidder inquiry and must be made as noted in the Notice to Bidders section of the Notice to Bidders and Special Provisions.

Indicate receipt of this addendum by filling in the number of this addendum in the space provided on the signature page of the Bid book.

Submit bids in the Bid book you now possess. Holders who have already mailed their book will be contacted to arrange for the return of their book.

Inform subcontractors and suppliers as necessary.

This addendum is available for the Contractors' download on the Web site:

http://www.dot.ca.gov/hq/esc/oe/project ads addenda/08/08-478304

If you are not a Bid book holder, but request a book to bid on this project, you must comply with the requirements of this letter before submitting your bid.

Sincerely,

RERECCA D HARNAGEL

Chief, Office of Plans, Specifications & Estimates

Office Engineer

Division of Engineering Services